

CERTIFICATE of Conformity



Certificate No.: MK 69262571 0001
Test Report No.: 28252353 002
Certificate Holder: PJSC ODESKABEL
Nikolaevskaya doroga, 144, 65102 Odessa, UKRAINE
Product: Photovoltaic cable
Identification: Type designation: H1Z2Z2-K
Cross section: 1x4mm²; 1x6mm²
Rated Voltage AC: U0/U AC: 1/1kV
Rated voltage DC: 1,5kV DC (conductor-conductor and
conductor-earth)
Max. permitted voltage DC 1,8kV
Range of
temperature: -40°C to +90°C
Max conductor
temperature: 90°C (120°C for 20000 h)
Insulation
material: Halogen free cross-linked
polyethylene compound
Sheath material: Halogen free cross-linked
polyethylene compound
Trade mark: ODESKABEL
Tested according to: EN 50618:2014

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date of Issue:
Budapest, 2020-09-22

A handwritten signature in black ink, appearing to read "Kristof Kertesz".

Kristof Kertesz

TÜV Rheinland InterCert Kft. – Product Certification Body — H-1143 Budapest, Gizella út 51-57. — www.tuv.com

Validity of certificate can be checked on www.CERTIPEDIA.com